CEBEDEAU

CEBEDEAU

Allée de la découverte, 11, 4000 LIEGE (Sart-Tilman)

Certificate of analysis

Assessment of germicidal properties of CINTROPUR TRIO-4100 UV-systems

For a transmittance at 254 nm higher than 90 % of water, the CINTROPUR TRIO-4100 UV system deliver:

a fluence higher than 250 J/m^2 at a water flow rate comprised between 0 et 2.62 m^3/h.

a fluence higher than 400 J/m^2 at a water flow rate comprised between 0 et 1.64 m^3/h.

Christophe Meunier
Responsable R&D

Stéphane Nonet
Directeur

Etude : 2016/507 **02/05/2017**

Essais réalisés avec le soutien de

www.enmieux.be

FEDER UNION EUROPEENNE Wallonie

LE FONDS EUROPÉEN DE DÉVELOPPEMENT RÉGIONAL ET LA WALLONIE INVESTISSENT DANS VOTRE AVENIR