



Allée de la découverte, 11, 4000 LIEGE (Sart-Tilman)

Certificate of analysis

Assessment of germicidal properties of CINTROPUR TRIO-4100 UV-systems

For a transmittance at 254 nm higher than 90 % of water, the CINTROPUR TRIO-4100 UV system deliver:

a fluence higher than 250 J/m² at a water flow rate comprised between 0 et 2.62 m³/h.

a fluence higher than 400 J/m² at a water flow rate comprised between 0 et 1.64 m³/h.



Christophe Meunier
Responsable R&D



Stéphane Nonet
Directeur

Etude : 2016/507

02/05/2017

Etude : 2016/507

Essais réalisés avec le soutien de



LE FONDS EUROPÉEN DE DÉVELOPPEMENT RÉGIONAL
ET LA WALLONIE INVESTISSENT DANS VOTRE AVENIR



Page 1 de 1