



Chemin des Chevreuils, 3, 4000 LIEGE (Sart-Tilman)

Certificate of analysis

Assessment of germicidal properties of CINTROPUR 10000 UV-systems

For a transmittance at 254 nm higher than 90 % of water, the CINTROPUR 10000 UV system deliver:

a fluence higher than 250 J/m² at a water flow rate comprised between 0 et 4.79 m³/h.

a fluence higher than 400 J/m² at a water flow rate comprised between 0 et 2.99 m³/h.



CEBEDEAU a.s.b.l.
3, Chemin des Chevreuils - Bat. B53
B - 4000 Liège
Tél. 04/252 12 33 - Fax. 04/254 03 63
T.V.A. : BE 402.381.833

Christophe Meunier
Responsable R&D



Stéphane Nonet
Directeur

Etude : 2013/325

25/08/2014

Essais réalisés avec le soutien de



www.enmieux.be



LE FONDS EUROPÉEN DE DÉVELOPPEMENT RÉGIONAL
ET LA WALLONIE INVESTISSENT DANS VOTRE AVENIR



Wallonie